

## **Removable Lip Seal Flood Barrier (WK Model# FP-LS) Specifications**

### **Part 1 – General**

- 1.01 **Description:** Provide flood barrier(s) factory assembled with frame(s) and all operating components in accordance with contract specifications and approved drawings.
- 1.02 **Acceptable Manufacturers:** Flood barrier shall be as manufactured by Walz & Krenzer, Inc (203-267-5712; sales@wkdoors.com).
- 1.03 **Standards:** Comply with the provisions of the following (as applicable):
  - A. AISC “Specifications for Design, Fabrication, and Erection of Structural Steel for Buildings”.
  - B. The Aluminum Assoc. “Aluminum Design Manual”.
  - C. AWS Structural Welding Code D1, D1.2, D1.3, D1.6.
  - D. ASME Structural Welding Code Section IX.
  - E. FEMA Bulletin 3-93, #102 & #114.
- 1.04 **Submittals:**
  - A. Manufacturers Data: Submit installation and maintenance manuals for flood barrier.
  - B. Shop Drawings: Submit shop drawings approved by licensed Professional Engineer for flood barriers including dimensional plans, elevations, sections, details for all mountings/connections, and parts list.
  - C. Calculations (optional for critical applications): Submit calculations approved by licensed Professional Engineer verifying the flood barrier’s ability to withstand the design pressure loading.
  - D. QA Submittals: Submit test reports showing compliance with specified performance characteristics.
- 1.05 **Qualifications:** Manufacturer shall present evidence attesting to at least five years successful experience in the design and manufacture of similar closures.

### **Part 2 – Products**

- 2.01 **Product Description:** Flood barrier shall be Model FP-LS as manufactured by Walz & Krenzer, Inc.
- 2.02 **Materials:**
  - A. Panel: 5051-H32 aluminum plate with 6061-T6 aluminum stiffeners.
  - B. Frame: 304 stainless steel (options include aluminum and 316 stainless steel).
  - C. Latches: stainless steel sliding latch bolts.

- D. Gasket: Walz & Krenzer EPDM lip seal gasket, 60 duro with fully molded corners.
- E. Finish: aluminum panel painted with INSL-X CheckRust acrylic paint. Stainless steel frame to be abrasively cleaned only.
- F. Grab Handle and Panel Stops: 6061-T6 aluminum.
- G. Storage brackets: ASTM A-36 steel.

### **2.03 Design:**

- A. Design Pressure: # (in feet of water). Specify seating (pushing gate closed) or unseating direction (pushing gate open).
- B. Side frames are available as angles for mounting on the exterior face of the wall surface, or as flatbars for mounting inside door jambs.
- C. Bottom frame is a ½” flatbar, which can be recessed ½” into floor surface to achieve a flush bottom sill.
- D. Corners of flood barriers have small (2”) radius.
- E. Frame(s) shall have mounting holes for expansion anchors (options include masonry subframe with welded anchors for embedment in concrete).
- F. Two storage brackets per panel included.
- G. Flood barriers over 10’ in width and 6’ in height may require multiple panels, available in both side by side, and/or stacked configurations. Side by side multiple panel flood barriers are provided with removable braces (and without mullions).
- H. Additional requirements such as hydrodynamic loads, impact loads and breaking wave loads shall be added as required by the specific application.

### **2.04 Quality Assurance:**

- A. Perform shop operational test.
- B. Perform shop leakage test.
- C. Liquid Penetrant Test (for critical applications): Welds in the “potential” leak path shall be liquid penetrant inspected in accordance with Appendix VIII of Section VIII of ASME Code Div. 1.

## **Part 3 – Execution**

### **3.01 Fabrication:**

- A. The finished product shall be rigid, neat in appearance, and free from all defects, warps, and buckles. All exposed joints and corners shall be well rounded.
- B. The panel and frame shall be flat within 1/8” in any 6’ length.
- C. All butt welds in frame to be full penetration welds.

### **3.02 Installation:**

- A. Install flood barrier in accordance with manufacturer’s instructions and approved shop drawings.

- B. After installation, perform field operational test per manufacturer's instructions to verify seal.
- C. Finish paint (if applicable) after installation.

**3.03 Warranty:** Flood barrier shall operate satisfactorily and be free of defects in material and workmanship for a period of not less than one year from the date of delivery.